



**REROOF WINDSTORM LOSS  
MITIGATION CERTIFICATION  
FLORIDA STATUTE 553.844**

The following information is to be provided by roofing contractor or owner/builder on all re-roof applications for the purpose of obtaining compliance with recent changes to State Statute and referenced "Hurricane Mitigation Manual" & Current Florida Building Code. Effective date: October 1, 2007 & December 31st, 2020 (7th ed (2020) FBC)

**Note:** These requirements apply to all structures built prior to implementation of the 7th ed (2020) Florida Building Code.

- Value: show proof of insured value of all structures or a copy of the ad-valorem tax value.

**All re-roofs** regardless of value shall comply with the following:

**Re-nailing:** All sheathing and decking shall be re-nailed per 706.7.1 and shall have underlayment per 905.1.1

- **Existing fasteners** that are 8d clipped head, round head or ring shank and spaced 6 in. or less o.c. may be counted. **Additional fasteners** shall be 8d roof sheathing ring shank nails ASTM F1667 classification RSR5-01, spaced at 6 in. o.c. along framing. (Per 7th ed (2020) FBC/Existing 706.7.1)
- Indicate below which method is to be used to satisfy the **secondary water barrier requirements:** Call out approved product on Product Approval Checklist.

\_\_\_\_\_ a.) Apply a self-adhering polymer modified Bitumen underlayment complying with ASTM D1970 applied over the entire roof deck. **(Allowable for slopes greater than 2:12 and above)** - (WIND PRESSURES GREATER THAN 90 PSF FOR TILE WILL REQUIRE PRODUCT APPROVAL & FBC CODE REQUIREMENTS, I.E... BASE PLY, AND UNDERLAYMENT, SEE MFGS SPECS OR FBCR 905.1.1)  
**OR**

\_\_\_\_\_ b.) Apply two layers of felt underlayment complying with ASTM D226 Type II or ASTM D4869 Type III or IV or two layers of a synthetic underlayment meeting the performance requirements specified, lapped and fastened as specified. Apply a 19-inch strip of underlayment felt parallel to and starting at the eaves. Starting at the eave, apply a 36-inch wide sheet of underlayment, overlapping successive sheets 19 inches; end laps shall be 6 inches and offset by 6 feet. Where felt underlayment is used it must be 30# or equivalent. **(Allowable for slopes greater than 2:12 and above)**  
**OR**

\_\_\_\_\_ c.) Apply a minimum 4-inch wide strip of self-adhering polymer-modified bitumen complying with ASTM D1970 or a minimum 3 ¾-inch wide strip of self-adhering flexible flashing tape complying with AAMA 711, applied over all joints in roof decking. Underlayment shall be applied shingle fashion, parallel to and starting from the eave and lapped 4 inches, end laps shall be 6 inches and shall be offset by 6 feet. The underlayment shall be attached to a nailable deck with two staggered rows in the field of the sheet with a maximum fastener spacing of 12 inches o.c. and one row at the end and side laps fastened 6 inches o.c. Where felt underlayment is used it must be 30# or equivalent. **(Allowable for slopes greater than 4:12 and above. This System is not allowed for slopes less than 4:12. Use System a or b if slope is less than 4:12)**

**All Structures valued at \$300,000 or more must have a completed Martin County Reroof Windstorm Loss Mitigation Compliance Affidavit.**

\_\_\_\_\_ **YES:** Value over \$300,000.00

\_\_\_\_\_ **NO:** Value over \$300,000.00

**ADA Accessibility Disclosure Statement** – This document may be reproduced upon request in an alternative format by contacting the County ADA Coordinator (772) 320-3131, the County Administration Office (772) 288-5400, Florida Relay 711, or by completing our accessibility feedback form at [www.martin.fl.us/accessibility-feedback](http://www.martin.fl.us/accessibility-feedback).